

IOWA STATE UNIVERSITY

Department of Electrical and Computer Engineering

115/34.5kV Solar Plant & Substation

Client: Black & Veatch: Adam Schroeder, Elymus Schaffer, Utsavee Desai

Faculty Advisor: Venkataramana Ajjarapu



BLACK & VEATCH



**Andrew M Chizek, David W Ntako, Ben Palkovic, Mohamed A Sam,
Sergio Sanchez Gomez & Dallas R Wittenburg**

| **Senior Design Team 41**

| **05/09/2025**

Group Roles

- Andrew Chizek: Researcher and Drafter
- David Ntako: Researcher and Drafter
- Ben Palkovic: Meeting Recorder and Drafter
- Mohamed Sam: Testing and submission
- Sergio Sanchez Gomez: Technical Writer and Editor
- Dallas Wittenburg: Client and Advisor Communications

Project Overview

Fall Semester: Solar Farm



Spring Semester: Substation



- Make a complete design of a solar farm and substation including all drawings, calculations, and tests needed for construction

Project Motivation



Users

- Utility companies
- Citizens who use electricity

Needs

- Clean energy
- Uninterrupted supply of power
- Optimal use of land and budget
- Adhere to all safety codes and regulations
- Sustainable

Project Plan



Deliverables

Fall Semester: Solar Farm

- Array Parameter Tool
- String, Rack, and Array Layouts
- Plant Characteristics
- Voltage Drop Calculations
- Datasheets
- Site Selection


Spring Semester: Substation

- One-Line
- Equipment Layout
- Grounding Study and Calculations
- AC and DC Calculations
- ETAP Simulations



Solar Site Selection

Deming, New Mexico

- Optimal cost
- High solar irradiance
- Barren, useless land
- Nearby high voltage transmission lines



Solar Array Overview



PV Modules

- 700W
- Voc: 47.9 V
- Isc: 18.49 A

Combiner Box

- 1500 V
- 320 A

Inverter

- 1500 V input
- 4095 kW


115/34.5kV Solar Plant & Substation
Senior Design Project

Solar Array Overview


Array Parameter Tool

	String Size				Electrical Rack Size			CB capacity				Array Design			Array Size		
				Designer Choice		Landscape											
Location Dependent	Min Temp	4.44 C		Datasheet Datasheet	Module width	7.82 ft		Datasheet (STC)	mod/string Isc	18.49 A		Designer Choice	Racks per row	5	Designer Choice	tilt	30
Datasheet (STC)	Voc	47.9 V			module height	4.27 ft			NEC sectic multiplier	1.25		Designer Choice	rows per Array	26		table height proj	7.395857 ft
Datasheet (STC)	Ref temp	25 C		Designer Choice Designer Choice	Rack width	29 modules	Irr.		multiplier	1.25							
					Rack height	2 modules			max Isc	28.89063 A		Designer Choice	Racks removed	0	Designer Choice	row space	9 ft
Datasheet	Temp Coeff of Voc	-0.0029 /C			Modules per rack												
	Temp delta	-20.56			Rack width	226.78 ft		Designer Choice:	allowed current	320 A			Total Racks/Array	130		pitch	16.39586 ft
	temp correction	1.06			Rack height	8.54 ft			is this disconnect A?							Space for Inverter Maintenance	ft
	V0c corrected	50.75599						200, 400A etc.	strings per CB	11.07626			Total modules	7540		Array height	426.2923 ft
									Round down:	11							
Confirm possible with Panel type chosen	string voltage	1500 V							racks per CB	5.5		Datasheet (STC)	module capacity	700 W		Array width	1133.9 ft
	String size	29.55316		Designer Choice:									dc capacity	5278 kW		Ground Coverage Ratio	0.520863
	string size	29															
	Actual String Voltage	1471.9										Designer Choice	inverter capacity	4095 kW			
												Provided: Industry standard	ILR	1.288889			
												1.3					
	Input Information =																

Solar Farm Overview



Solar Array Overview



Voltage Drop Calculations

DCB	Strings per Rack	IMP for String	String Length	String wire size	String Conductor resistance	String resistance	Voltage Drop of String	IMP for Jumper	Jumper Length	Jumper wire size	Jumper resistance	Jumper resistance	Voltage Drop of Jumper	Voltage Drop of String	Voltage Drop of Jumper
DCB#-##	per rack	Amp	feet	AWG	Ohm/kft	Ohm	Volts	Amp	feet	AWG	Ohm/kft	Ohm	Volts	percent	percent
DCB1-01	2	14	226.87	10	1.2400	0.5448151	7.8769264	28	569	8	0.7640	0.8409313	24.344096	0.525128427	1.622939733
DCB1-02	2	14	226.87	10	1.2400	0.5448151	7.8769264	28	342	8	0.7640	0.5061071	14.632128	0.525128427	0.9754752
DCB1-03	2	14	226.87	10	1.2400	0.5448151	7.8769264	28	115	8	0.7640	0.1703152	4.92016	0.525128427	0.328010667
DCB1-04	2	14	226.87	10	1.2400	0.5448151	7.8769264	28	342	8	0.7640	0.5061071	14.632128	0.525128427	0.9754752
DCB1-05	2	14	226.87	10	1.2400	0.5448151	7.8769264	28	569	8	0.7640	0.8409313	24.344096	0.525128427	1.622939733
Combiner Name		from Array Parameter	panels in string* panel width	IMP is 1.25 AWG size above that	Table 8 NEC						Table 8 NEC				

$$V_d = \frac{I \times 2 \times d}{1000 \text{ ft} / \text{kft}} \times \left(\frac{\Omega}{\text{kft}} \right)$$

Where:

V_d = voltage drop

d = route length of dc cable in feet (2 x adjusts for total circuit wire length)

I = dc current in amperes (commonly I_{mp})

Ω/kft = ohms/thousand feet (resistance)

$$\text{Voltage drop (in percentage)} = \frac{V_d}{V_{MAX}} \times 100$$

Substation Overview


Ring Bus Configuration

Pros

- Very Reliable
- Flexible

Cons


- Complex relaying
- More land
- More expensive




Relaying Plan

Key Components

- Voltage Transformer (VT)
- Current Transformer (CT)
- Relays
 - **Line Protection:**
SEL 311L and 311C
 - **Feeder and BF:**
SEL 751 and 352
 - **Transformer Prot:**
487E and 587





Key Plan



Key Plan

Things to Consider


- Bus spacing
- Phasing
- Land constraints



Key Plan

Things to Consider

- Bus spacing
- Phasing
- Component sizes



115/34.5kV Solar Plant & Substation
Senior Design Project

AC calculations

AC STUDY							
		Quantity	Load/Unit (W)	Amps (ea)	Voltage (V)	Total (W)	Amps Total
AC Panel - Control Building	Breaker Recepticle and Lights	8	210	1.75	120	1680	14.00
	Transformer Fans	2	24000	100	240	48000	200.00
	Transformer Sump Pump	2	2000	8.333333	240	4000	16.67
	Control House Lighting	20	36	0.3	120	720	6.00
	Yard Lights (Assuming lights are off)	8	55	0.458333	120	440	3.67
	HVAC System	1	10000	41.66667	240	10000	41.67
	Fire Detection Equipement	1	150	1.25	120	150	1.25
	Exhaust Fan	1	132	1.1	120	132	1.10
	AC Battery Charger	1		0	240	0	0.00
	Power Outlet	10	180	1.5	120	1800	15
	Breaker Heaters	8	640	5.333333	120	5120	42.666667
				0	1	0	0
				0	1	0	0
	Worst Case Tripping						
	High Side Breaker Trip	1	720	3	240	720	3
	Low Side Breaker Trip	2	720	3	240	1440	6
Total Worst Case AC Panel Load						72042	342.02
Total Worst Case Load (+10%)						79246.2	376.21833

80 kVA station service transformer
450 A MTS

115/34.5kV Solar Plant & Substation
Senior Design Project

DC calculations

Components	Load Current (A)	Nominal Voltage (V) DC	Inception and Active Shutout Time	Number of components	Total Load Current (A)	Power Requirement	Power (Units)
34.5kV Breaker:	Tripping Current: 3.3	70 – 140	0 -1	6	Tripping Current:19.8	343	W
	Closing Current: 2.6	90 - 140			Closing Current :15.6	364	W
115kV Breaker:	Tripping Current : 6.6	125	239- 240	2	Tripping Current: 13.2	1050	W
	Closing Current : 3.6	125			Closing Current : 7.2	950	W
SEL-311C	0.20	125	1 - 240	8	1.60	25	W
SEL-311L	0.20	125	1 - 240	8	1.60	25	W
SEL-587	0.044	125	1 - 240	2	0.08	6	W
SEL-487E	0.280	125	1 - 240	2	0.56	35	W
Battery Monitoring Equipment	0.024	50 -180	1 - 240	1	0.02	6	VA
DC Ammeter	0.048	125	1 - 240	1	0.048	3	VA
DC Voltmeter	0.048	120	1 - 240	1	0.048	3	VA
SACO Annunciator (L8)	0.150	125	1 - 240	2	0.30	15	W
Edwards Bell	0.012	125	1 - 240	1	0.012	1.5	VA
Power Line Indicating Lamps (LEDs)	0.017	125	1 - 240	8	0.136	2.125	W

60 Cell Sysem	Continuous Load	Discontinuous Load Current
	4.404A	19.8 A

Power Supply Burden (W)	t=240min	t = 1 min
	4.404 A	37.404

IEEE-485


Standards

IEEE Standards

- IEEE 80 - Grounding
- IEEE 485 – Lead acid battery sizing
- IEEE 605 – Bus design

NEC Standards

- Section 210-20(a) - Overcurrent protection devices
- Section 110-14(c) - Conductor Sizing



Testing

Generation Bus				Voltage		Generation			Mvar Limits	
ID	kV	Type	Sub-sys	% Mag.	Angle	MW	Mvar	% PF	Max	Min
Bus_3	34.500	Mvar/PF Control	1	100.0	0.0	11.885	0.000	100.0		
Bus_4	34.500	Mvar/PF Control	1	100.0	0.0	15.846	0.000	100.0		
Bus_5	34.500	Mvar/PF Control	1	100.0	0.0	15.846	0.000	100.0		
Bus_6	34.500	Mvar/PF Control	1	100.0	0.0	15.846	0.000	100.0		
Bus_7	115.000	Swing	1	100.0	0.0					
Bus_8	115.000	Swing	1	100.0	0.0					
						59.423	0.000			

The generation totals to **59.423 MW**, which is nearly the target **60 MW** design goal.

All voltages are regulated at **100%**, and reactive power is **0.000 MVAR**, confirming the power factor is 1.0 across all generator buses.

Conclusions

Group Member Contributions

- Andrew Chizek: Component Selection, Section Views, Grounding Physical Drawings
- David Ntako: Component Selection, DC Calculation
- Ben Palkovic: One-Line Diagram, Physical and Relaying, Key Plan, Section Views
- Mohamed Sam: ETAP, Load Flow & Short Circuit, Three-Line Diagram
- Sergio Sanchez Gomez: DC Calculation, Battery Sizing, BOM
- Dallas Wittenburg: Substation Grounding, Layout, Conduit Plan, ETAP

All Members: Weekly Meetings, Rotating Leadership Roles



IOWA STATE UNIVERSITY

Department of Electrical and Computer Engineering

THANK YOU

| Senior Design Team 41

| 05/09/2025