

IOWA STATE UNIVERSITY

Department of Electrical and Computer Engineering



BLACK & VEATCH

115/34.5kV Solar Plant & Substation

Senior Design Project

Andrew M Chizek, David W Ntako, Ben Palkovic Mohamed A Sam, Sergio Sanchez
Gomez & Dallas R Wittenburg

| Senior Design Team 41

| 04/14/2025

AGENDA

- Safety Moment
- New Technology
- AutoCAD Updates
- ETAP
- BOM
- Discuss the Rest of the Semester

SAFETY MOMENT

LOTO

What Is the Meaning of LOTO?

LOTO stands for **Lockout/Tagout**. It's a safety process used to **turn off machines and keep them off** while maintenance or repairs are being done.

According to OSHA, LOTO procedures **prevent an estimated 50,000 injuries and 120 fatalities each year**.

Why is LOTO important?

- It **prevents accidents** by stopping machines from starting unexpectedly.
- It **keeps workers safe** during maintenance.
- It **saves time** by helping teams work safely and efficiently.
- It **clearly shows** when a machine is being worked on, so others don't turn it on.



NEW TECHNOLOGY

IoT Substation Monitoring

1. Definition:

A system that uses smart sensors, communication networks, and data analytics to monitor substation equipment in real time, enabling automated maintenance and improved operational efficiency.

<https://www.iotforall.com/empowering-the-grid-iot-substation-monitoring>



IoT Substation Monitoring

2. Key Components:


- Sensor Networks: Monitor voltage, current, temperature, etc.
- Communication Infrastructure: Transmits data using protocols like MQTT.
- Edge Computing: Processes data locally for faster decisions.
- Cloud Platforms: Stores and visualizes data remotely.
- Predictive Analytics: Detects issues before failures occur.

3. Benefits:

- Real-Time Monitoring: Instant visibility of system status.
- Predictive Maintenance: Prevents failures, reduces downtime.
- Efficient Resource Use: Smarter maintenance and upgrades.
- Improved Safety: Fewer manual checks in dangerous areas.
- Cost Savings: Lower repair and energy costs.
- Fast Fault Response: Quick alerts and remote action.


AutoCAD

Section C



AutoCAD


Key Plan



115/34.5KV Solar Plant & Substation
Senior Design Project

AutoCAD


Key Plan



AutoCAD

Section A

- Still updating details based on the comments left



Critical Report

Device ID	Type	Condition	Rating/Limit	Unit	Operating	% Operating	Phase Type
PVA_1	PV Array	Overload	70.924	Amp	1225.253	1727.6	3-Phase
PVA_2	PV Array	Overload	70.924	Amp	1225.253	1727.6	3-Phase
PVA_3	PV Array	Overload	70.924	Amp	1225.253	1727.6	3-Phase
PVA_4	PV Array	Overload	79.494	Amp	1225.253	1541.3	3-Phase
T_1	Transformer	Overload	90.000	MVA	145.620	161.8	3-Phase
T_2	Transformer	Overload	90.000	MVA	145.620	161.8	3-Phase

Info

PV Panel

PV Array

Inverter

Physical

Time Domain

Remarks

Comments

PV Array - Total Rated

Volts,dc

301600

kW,dc

79170

Amps,dc

262.5

Inverter

ID

Inv20

kW

V

FLA

%EFF

DC

4709

955

4931

90

kVA

kV

FLA

%PF

AC

4238.1

34.5

70.92

100

Inverter Editor...

☒ Maximum Power Point Tracker (MPPT)

Inverter to PV Array Cable

Info

Rating

Converter

SC Model

FRT

Generation

Capability

Harmonic

Reliability

Remarks

Comment

DC 4095 kW 1500 VAC 34.5 kV 4054.1 kVA

DC Rating

kW4095V1500Vmax110%Vmin90%

FLA2730

Efficiency

%Load100755025

%Eff.99909090

Imax

105%

AC Rating

kVA4054.1kV34.5FLA67.84

Normal Operating Voltage

Vmin90%Vmax110%

%PF100

AC Grounding

☐ Grounded

Inv24

OK

Cancel

Info

PV Panel

PV Array

Inverter

Physical

Time Domain

Remarks

Comments

PV Panel

Watt / Panel700

in Series38

in Parallel198

PV Array (Total)

of Panels7524

Volts,dc1520

kW,dc5266.8

Amps,dc3465

Irradiance Calc.

	Generation Category	Irradiance	Ta	Tc	MPP kW
▶ 1	Design	1000	30	56.3	5381.87
2	Normal	900	30	53.6	4843.69
3	Shutdown	800	30	51	4305.5
4	Emergency	700	30	48.4	3767.31
5	Standby	600	30	45.8	3229.12
6	Startup	500	30	43.1	2690.94
7	Accident	400	30	40.5	2152.75
8	Summer Load	300	30	37.9	1614.56
9	Winter Load	200	30	35.3	1076.37
10	Gen Cat 10	100	30	32.6	538.19


PVA46

OK

Cancel

115/34.5kV Solar Plant & Substation
Senior Design Project

| 10



ETAP Arc Flash

- Type of Report
- Incident Energy?
- Arc Flash Boundaries?

Project:	ETAP	Page:	1
Location:	24.0.1E	Date:	04-21-2025
Contract:		SN:	IASTATEPL
Engineer:	Study Case: BusFault	Revision:	Base
Filename: Online_1_ms		Config.:	Normal

Arc Flash Analysis														
½ Cycle Calculation Method														
Arc Fault Location				Correction Factors			Incident Energy							
Element ID	Connected Bus ID	Enclosure		Electrode Config.	Prefault kV	Iarc Var. (%)	Encl. CF (pu)	Ibf" (kA)	Ia" (kA)	Source PD Ia" (kA)	FCT (Cycles)	Source PD ID	IE (cal/cm²)	AFB (ft)
		ID	Type											
Bus_7	Bus_7		Bus Arc Fault	VCB		0		1.325	1.325	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00
SW29	Bus_7		Source PD Line Side	VCB		0		1.325	0.000	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00
CB2_1	Bus_7		Source PD Line Side	VCB		0		1.325	0.000	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00
SW21	Bus_7		Source PD Line Side	VCB		0		1.325	0.000	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00
SW30	Bus_7		Source PD Line Side	VCB		0		1.325	0.000	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00
CB2_2	Bus_7		Source PD Line Side	VCB		0		1.325	0.000	0.000		Cannot be Determined	0.000	
												(+) Total =	0.000	0.00

BOM

Solar Component						
Component type	Model Number	Quantity	Price	Datasheet link	Total Price	Pricing link
PV Panels	TOPBiHiKu7 CS7N-700TB-AG	113,100	\$223.00	Link	\$25,221,300.00	
Combiner boxes	CA1500-24-20S	360	\$2,156.00	Link	\$840,840.00	
Inverters	SLG-330-0279	15	\$119,210.14	Link	\$1,788,152.00	
Conduit					0	
Large wires (MCM)					0	
Substation Component						
Component type	Model Number	Quantity	Price	Datasheet link	Total Price	Pricing link
SEL-311C	311#01	2	\$6,590.67	Link	\$13,181.34	Link
SEL-311L		2	\$7,130.00	Link	\$14,260.00	Link
SEL-352	352#01	6	\$4,782.50	Link	\$28,695.00	Link
SEL-751	751#12	4	\$2,000.73	Link	\$8,002.92	Link
SEL-487E	487E#01	2	\$10,643.19	Link	\$21,286.38	Link
SEL-587	587#01	2	\$2,712.64	Link	\$5,425.28	Link
T (POWER XMFR)	XD 115kV/34.5 90 MVA	2				
CB1		2	\$11,900.00	Link	\$23,800.00	
CB2		6		Link	\$0.00	
DS1		12	\$8,000.00	Link	\$96,000.00	Link
DS2		6		Link	\$0.00	
LA1						
LA2						
PT						
CT						
Battery						
MIS Component						
Component type	Model Number	Quantity	Price	Datasheet link	Total Price	Pricing link
Fence	Solidlock® Pro 20 2096-6 12.5 ga 330' High Tensile Fixed Knot Game Fence	330	\$643.00	Link	\$212,190.00	Link
Bus Bar						

End of Semester

- Lightning Protection Calcs?
- Industry Review Panel is May 9th
 - Present to BV before?

Substation Deliverables

Drawings/Documents

- Key Protection Diagram (One-line)
- Yard Equipment Layout
- Grounding Study and Calculations
- Lightning Protection Calculations
- AC & DC Battery Calculation
- ETAP Simulation and Calculations
- Additional Deliverable possibilities (depending on time):
 - Three-line Diagrams
 - AC/DC schematics
 - BOM
 - Electrical Layout Elevations
 - Lightning Calc/Protection

Documentation

- Project Design Document (Needs to be worked on throughout the project)
- Project schedule (Gantt Chart)
- Project budget
- Materials List

IOWA STATE UNIVERSITY
Department of Electrical and Computer Engineering

THANK YOU

| Senior Design Team 41

| 02/03/2025